

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20181228-EX27954  
**Report Reference** EX27954-20181228  
**Issue Date** 2018-DECEMBER-28

**Issued to:** K.D Industries Inc  
Plot MOO708 12th Roundabout  
Jebel Ali Free Zone  
Opposite Inter Taym FZCO  
Dubai  
17810 UNITED ARAB EMIRATES

**This certificate confirms that  
representative samples of**

**METALLIC SPRINKLER PIPE**

Schedule 40 Black or Galvanized steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 6 in. sizes as per ASTM A 53, Grade A, type E.

Schedule 10 Black or Galvanized steel pipe in the 1-1/4, 1-1/2, 2, 2-1/2, 3, 4 in. sizes as per ASTM A 795 and ASTM A 53, Grade A, type E


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 852, Metallic Sprinkler Pipe for Fire Protection Service  
**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

